
Plan Review Summary

Building Information

Project Name:	CODA Tenant Fit Up Floors 14-16	Floor/Room #:	Floors 14-16
Building #:	207	Department:	Facilities Design & Construction
Occupancy Type:	Business	Budget:	\$35M
Construction Type:	IB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Devyn Blackston
Architect/Engineer of Record:	Matt DiPiro
Construction Manager:	Chris Sanders
Aim Project Number:	0009-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/14/2019
Disposition:	Approved	Date Completed:	2/6/2019

Status Statement

Note: Fire Alarm System Installation 14-16 floors.

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation
- 3.

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

2019-FA-015
