

---

## Plan Review Summary

---

### Building Information

|                    |                               |                 |                        |
|--------------------|-------------------------------|-----------------|------------------------|
| Project Name:      | Ford ES&T Kaiser Research Lab | Floor/Room #:   | 3107                   |
| Building #:        | 147                           | Department:     | College of Engineering |
| Occupancy Type:    | Business                      | Budget:         | \$245,000              |
| Construction Type: | IIB                           | Type of Review: | Fire Alarm             |

---

### Project Management

|                               |                  |
|-------------------------------|------------------|
| Project Manager:              | Bill Oswell      |
| Architect/Engineer of Record: | Kyle Epstein     |
| Construction Manager:         | Mitchell Shelton |
| Aim Project Number:           | 0479-2018        |

---

### Reviewer Information

|                |              |                 |           |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received:  | 2/27/2019 |
| Disposition:   | Approved     | Date Completed: | 2/28/2019 |

---

### Status Statement

Note: Fire Alarm; 1 smoke detector

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2019-FA-052
-