

---

## Plan Review Summary

---

### Building Information

Project Name:	NEETRAC Phase IV Expansion Building	Floor/Room #:	New Building
Building #:	777	Department:	NEETRAC
Occupancy Type:	Business	Budget:	\$1,800,000
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Stuart Thiel, Plexus R + D Architecture
Construction Manager:	Kynthia Gaines
Aim Project Number:	0410-2017

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/11/2019
Disposition:	Approved	Date Completed:	3/20/2019

### Status Statement

Note: Fire Alarm System Installation

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm; As-builts and Central Station Report submitted and approved before 100%

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2019-FA-068