

Plan Review Summary

Building Information

Project Name:	Howey Renovation (Dr. Evenbly)	Floor/Room #:	N205, N206
Building #:	081	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$145,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Mitchell Shelton
Aim Project Number:	0075-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/1/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/2/2019

Status Statement

Note: Swapping new devices for old devices

Review Comments:

1. Make sure all devices are labeled

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm

2019-FA-095