
Plan Review Summary

Building Information

Project Name:	Campus Safety Facility-AS BUILTS	Floor/Room #:	
Building #:	211	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$12,500,000
Construction Type:	IIB	Type of Review:	Fire Alarm-AS BUILTS

Project Management

Project Manager:	Krupali Davi
Architect/Engineer of Record:	Chad Saleeby
Construction Manager:	Chris Sanders
Aim Project Number:	C0346-2016

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/17/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/18/2019

Status Statement

Note: Fire Alarm As-built

Review Comments:

1. Devices N1L1D44, N1L1D72, N1L1D10, which appear to all be in the elevator shaft were not tested according to the central station testing report from Georgia Security. FYI, at final inspection these devices will need to be tested and verified through Georgia Security Central Station.
2. The fire alarm panel and system shall be compatible with the Onyx work station here in the GTFISO.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-117
-