

Plan Review Summary

Building Information

Project Name:	GTRI Cobb South-AS BUILTS L-12	Floor/Room #:	Whole Building
Building #:	763	Department:	GTRI
Occupancy Type:	Business	Budget:	\$24M
Construction Type:	IIB	Type of Review:	Fire Alarm-AS BUILTS

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Century Fire Protection Craig York
Construction Manager:	McCarthy Building Companies Dan Hesse
Aim Project Number:	0320-2016

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/23/2019
Disposition:	Approved	Date Completed:	4/24/2019

Status Statement

Note: Fire alarm as builds

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work
- 1.

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 201-FA-128