
Plan Review Summary

Building Information

Project Name:	Intake Center-Smithgall AS-BUILTS	Floor/Room #:	1
Building #:	123	Department:	Student Life
Occupancy Type:	Business	Budget:	\$2,710
Construction Type:	IIB	Type of Review:	Fire Alarm-AS Builts

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	HLG Studio, Sabrina Tate
Construction Manager:	Cork Howard, Mark Harwell
Aim Project Number:	2019-0101

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/29/2019
Disposition:	Approved	Date Completed:	5/15/2019

Status Statement

Note: Fire Alarm Devices

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 2019-FA-142
-