
Plan Review Summary

Building Information

Project Name:	Kappa Alpha Theta Sorority	Floor/Room #:	All
Building #:		Department:	
Occupancy Type:	Lodging or Rooming House	Budget:	
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Jeff Curtis (CANA)
Architect/Engineer of Record:	Hug and Associates
Construction Manager:	Lusk & Co-GC
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/13/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/14/2019

Status Statement

Note: Fire Alarm System

Review Comments:

1. Sheet FA-04: provide a horn/strobe in room 210 and not just a horn.
2. Duct detectors shall be installed in the supply and shall send a supervisory signal and not a fire alarm signal.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-159
-