
Plan Review Summary

Building Information

| | | | |
|--------------------|-------------------------|-----------------|----------------------------|
| Project Name: | GTRI Cobb South L12/B12 | Floor/Room #: | 1st Floor Warehouse |
| Building #: | 763 | Department: | GT Design and Construction |
| Occupancy Type: | Storage | Budget: | \$24M |
| Construction Type: | IIB | Type of Review: | Fire Alarm-Revision |

Project Management

| | |
|-------------------------------|---------------------------------------|
| Project Manager: | Nicolas Palfrey |
| Architect/Engineer of Record: | FLAD Architects/Structural Engineers |
| Construction Manager: | Dan Hesse/McCarthy Building Companies |
| Aim Project Number: | 0320-2016 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 5/15/2019 |
| Disposition: | Approved | Date Completed: | 5/16/2019 |

Status Statement

Note: Fire Alarm As-builts

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-160
-