
Plan Review Summary

Building Information

Project Name:	ROTC Interiors-O'Keefe Fire Alarm	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$999,999
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Warner Summers
Construction Manager:	
Aim Project Number:	0421-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/31/2019
Disposition:	Approved	Date Completed:	6/3/2019

Status Statement

Note: Reno fire alarm system

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 2019-FA-172
-