

Plan Review Summary

Building Information

Project Name:	Price Gilbert Library Renewal-Fire Alarm	Floor/Room #:	
Building #:	100	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$30M
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	Brian Tanner/Jeremy Kham
Construction Manager:	Philip Vann/Brasfield & Gorrie
Aim Project Number:	2014-0146

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/5/2019
Disposition:	Approved	Date Completed:	6/14/2019

Status Statement

Note: Fire alarm redesign

Review Comments:

1. Approved – Submit as builts and central station reports for 100%

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-178