
Plan Review Summary

Building Information

Project Name:	Architecture East Restrooms Renovations 026, 131,132,139	Floor/Room #:	Basement 026, 1st Floor 131, 132, 139
Building #:	076	Department:	Architecture/ADA
Occupancy Type:	Other	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Fenella Bryant
Aim Project Number:	0252-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/18/2019
Disposition:	Approved	Date Completed:	6/18/2019

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-200
-