

Plan Review Summary

Building Information

Project Name:	MRR FY19 Fire Alarm System Upgrades-Cherry Emerson	Floor/Room #:	All Floors
Building #:	066	Department:	GT Fire & Life Safety Office
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0336-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/24/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/24/2019

Status Statement

Note: Fire Alarm Upgrades

Review Comments:

1. FA1 – L1D026 add strobe
2. FA1- L2D001 add strobe
3. FA1 – 205 add strobe
4. Submit as-builts with riser diagram and central station report for 100%
5. System must tie into Onyx fire alarm

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-204