Georgia Environmental Tech Health & Safety Fire Safety

Plan Review Summary

Building Information			
Project Name:	Swann Room 320 Classroom Conversion	Floor/Room #:	320
Building #:	039	Department:	Ivan Allen College of Liberal Arts
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Fire Alarm
Project Management			
Project Manager:	CATUE SA		
Architect/Engineer of	Record: Maria Ceballos		
Construction Manage	r: Mitchell Shelton		
Aim Project Number:	0261-2019		
Reviewer Information			
Reviewer Name:	Jerry Marrison	Date Received:	7/1/2019
Disposition:	Approved	Date Completed:	7/1/2019
Status Statement			
Note: Adding 2 strobes			
Review Comments:			
1. Approved			
General Note:			
 Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work 			

Inspections Required:

- 1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-207