

Plan Review Summary

Building Information

Project Name:	Howey Lecture Hall Renovation	Floor/Room #:	South Ground Floor Corridor
Building #:	081	Department:	Capital Planning & Space Management
Occupancy Type:	Business	Budget:	\$16,390
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Christopher Atwel
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0096-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/15/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/15/2019

Status Statement

Note: Fire Alarm System; Fire Sprinkler monitoring devices, waterflow switch and valve tamper switch

Review Comments:

1. The devices to be installed shall be compatible with the existing fire alarm control panel and shall not exceed SLC points.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-224