
Plan Review Summary

Building Information

Project Name:	CRB 4th Floor Lab-Additional Devices	Floor/Room #:	442,442A, 444, 446, and 448
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	\$8,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Johnson Controls
Architect/Engineer of Record:	Johnson Controls
Construction Manager:	Ross Bongiovi
Aim Project Number:	0269-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/16/2019
Disposition:	Approved	Date Completed:	7/17/2019

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-225
-