

Plan Review Summary

Building Information

Project Name:	MRR FY19 Fire Alarm System Upgrades-Cherry Emerson	Floor/Room #:	All Floors
Building #:	066	Department:	GT Fire and Life Safety Office
Occupancy Type:	Business	Budget:	\$500,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0336-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/19/2019
Disposition:	Approved	Date Completed:	7/22/2019

Status Statement

Note: Fire Alarm System Upgrades

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>

Plan / Shop Drawings Required:

1. Fire Alarm As-builts

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm As-builts

Permits Issued:

1. Fire Alarm 2019-FA-234