

Plan Review Summary

Building Information

Project Name:	Alpha Sigma Pi	Floor/Room #:	
Building #:	313	Department:	Property Acquisition
Occupancy Type:	Lodging or Rooming House	Budget:	\$26,000.00
Construction Type:	IVB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Angela Williams
Architect/Engineer of Record:	Basesix
Construction Manager:	Angela Williams
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/16/2019
Disposition:	Approved	Date Completed:	8/20/2019

Status Statement

Note: New Fire Alarm

Review Comments:

1. New Alarm

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work
- 3.

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2019-FA-273