
Plan Review Summary

Building Information

Project Name:	GT Price Gilbert-Crosland Tower Renewal-Fire Alarm	Floor/Room #:	
Building #:	100	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$30M
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jeremy Kahm
Construction Manager:	Philip Vann
Aim Project Number:	2014-0146

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/3/2019
Disposition:	Approved	Date Completed:	1/7/2020

Status Statement

Note: Fire Alarm As-builts and Central Station Testing Report; Price-Gilbert

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permit Issued:

2019-FA-347
