

## Plan Review Summary

### Building Information

Project Name:	Howey Lecture Hall Renovation-Wing L 1-4	Floor/Room #:	Lecture Hall wing L1-4
Building #:	081	Department:	CPSM
Occupancy Type:	Business	Budget:	\$27,000
Construction Type:	IIIA	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Christopher Atwell
Construction Manager:	Nicolas Palfrey
Aim Project Number:	C0096-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/17/2019
Disposition:	Approved	Date Completed:	12/30/2019

### Status Statement

Note: Alarm panel swap

### Review Comments:

1. Approved with cellular dialer

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2019-FA-354