
Plan Review Summary

Building Information

Project Name:	Dalney Building-Fire Suppression	Floor/Room #:	All
Building #:	204	Department:	GTRC and PTS
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/7/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/8/2019

Status Statement

Note: Fire Sprinkler Revision

Review Comments:

1. A permit shall be required for the FM-200 System, which shall include plans and specifications of the system.
2. Please provide an additional standpipe connection on the other side of the stair wall where applicable to the questions asked. Also, fire sprinkler heads are not required in the parking garage where the questions appear on the plans.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-061