
Plan Review Summary

Building Information

Project Name:	Dalney Building Fire Suppression-Preaction System	Floor/Room #:	All
Building #:	204	Department:	GTRC(Office)& PTS (Garage)
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carsui
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/11/2019
Disposition:	Approved	Date Completed:	3/11/2019

Status Statement

Note: FM-200 System

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-065
-