

## Plan Review Summary

### Building Information

Project Name:	ROTC Sprinkler Install & Fire Alarm Upgrades	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$197,099.00
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	
Architect/Engineer of Record:	Warner Summers
Construction Manager:	Mitchell Shelton
Aim Project Number:	0459-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/8/2019
Disposition:	Approved	Date Completed:	5/9/2019

### Status Statement

Note: Addition of sprinkler

### Review Comments:

1. Plan approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Suppression System                      2019-FS-152