
Plan Review Summary

Building Information

Project Name:	New Campus Safety Facility Room 294	Floor/Room #:	2nd Floor/294
Building #:	211	Department:	Facilities Design and Construction
Occupancy Type:	Business	Budget:	\$12,500,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Don Makamson
Architect/Engineer of Record:	
Construction Manager:	Krupali Davi
Aim Project Number:	C0346-2016

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/20/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/20/2019

Status Statement

Note: Guardian Suppression System

Review Comments:

1. Balloon test for acceptance test must be done

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System 2019-FS-163
-