

Plan Review Summary

Building Information

Project Name:	ROTC Sprinkler Install & Fire Alarm Upgrades-REVISION	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D&C
Occupancy Type:	Business	Budget:	\$999,999
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	
Architect/Engineer of Record:	Warner Summers
Construction Manager:	Mitchell Shelton
Aim Project Number:	0421-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/29/2019
Disposition:	Approved	Date Completed:	5/29/2019

Status Statement

Note: Sprinkler addition ONLY

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

- | | |
|----------------------------|-------------|
| 1. Fire Suppression System | 2019-FS-169 |
|----------------------------|-------------|