
Plan Review Summary

Building Information

Project Name:	Cyber Security Labs 3201/3203/3353	Floor/Room #:	3201, 3203, 3353
Building #:	153	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$335,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Mark Wood
Aim Project Number:	0003-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/6/2019
Disposition:	Approved	Date Completed:	6/10/2019

Status Statement

Note: Relocation of 4 sprinkler heads

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-183
-