

Plan Review Summary

Building Information

Project Name:	Howey Renovation-Sprinkler Infrastructure	Floor/Room #:	First Floor South Corridor
Building #:	081	Department:	CPSM-Registrar
Occupancy Type:	Business	Budget:	\$100,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Todd Mowinski (N&B)
Construction Manager:	Mark Whitney (Gay Construction)
Aim Project Number:	C0096-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/7/2019
Disposition:	Approved	Date Completed:	6/10/2019

Status Statement

Note: Sprinkler line addition

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-184