
Plan Review Summary

Building Information

Project Name:	Dr. Vamvoudakis Flight Lab	Floor/Room #:	Rooms 101 and 103
Building #:	101	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$492,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Mitchell Shelton
Aim Project Number:	0004-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/9/2019
Disposition:	Approved	Date Completed:	7/12/2019

Status Statement

Note: Fire Sprinkler System; Ordinary Hazard Group II

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-216