
Plan Review Summary

Building Information

Project Name:	Bunger-Henry Battery Lab 433C	Floor/Room #:	433C
Building #:	086	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Hera
Construction Manager:	Mark Wood
Aim Project Number:	0228-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/14/2019
Disposition:	Approved	Date Completed:	8/15/2019

Status Statement

Note: 6 Fire Sprinkler Heads

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-271
-