

---

## Plan Review Summary

---

### Building Information

Project Name:	There Gastropub on 5th Tenant Upfit	Floor/Room #:	Ground Floor
Building #:	172	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$230,000
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Levi Salazar-Sola Tect Design Build
Construction Manager:	
Aim Project Number:	0270-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/22/2019
Disposition:	Approved	Date Completed:	8/23/2019

---

### Status Statement

Note: Relocating 1 head

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System 2019-FS-278
-