
Plan Review Summary

Building Information

Project Name:	Howey Physics of Living Systems Research Area	Floor/Room #:	N201, N202
Building #:	081	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$409,739
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Becky Williams
Construction Manager:	Mitchell Shelton
Aim Project Number:	0112-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/16/2019
Disposition:	Approved	Date Completed:	9/19/2019

Status Statement

Note: Fire Sprinkler System

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2019-FS-297
-