

## Plan Review Summary

### Building Information

Project Name:	GTRI 1663 CCRF Bldg. 5-Closed Area Expansion	Floor/Room #:	1st
Building #:	805	Department:	GTRI
Occupancy Type:	Business	Budget:	\$2.5M
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Spencer Bristol Engineering
Construction Manager:	Mitchell Shelton
Aim Project Number:	0313-2019

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/17/2019
Disposition:	Approved	Date Completed:	10/23/2019

### Status Statement

Note: Add and relocate fire sprinklers per plan

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

2019-FS-320