
Plan Review Summary

Building Information

Project Name:	Smith 300 Range Suppression & Fire-Alarm Tie In	Floor/Room #:	Third/300
Building #:	006	Department:	Housing O & M
Occupancy Type:	Business	Budget:	
Construction Type:	IIIA	Type of Review:	Fire Suppression

Project Management

Project Manager:	John Witt
Architect/Engineer of Record:	
Construction Manager:	
Aim Project Number:	19-217006

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/25/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	10/28/2019

Status Statement

Note: Adding Guardian Suppression Systems

Review Comments:

1. Suppression systems must be tied into fire alarm system

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Suppression System 2019-FS-327
-