

Plan Review Summary

Building Information

Project Name:	Campus Center-Exhibition Hall Fire Suppression	Floor/Room #:	All
Building #:	217	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$28,400,000.00
Construction Type:	IIB	Type of Review:	Fire Suppression-REVISION

Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Cooper Carry Inc.
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/11/2019
Disposition:	Approved	Date Completed:	11/20/2019

Status Statement

Note: Fire Sprinkler System: Exhibition Hall

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
8. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2019-FS-332