

## Plan Review Summary

### Building Information

Project Name:	Campus Center-Phase 1 Café-REVISION	Floor/Room #:	
Building #:	215	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$28,400,000
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Facilities-Design and Construction
Architect/Engineer of Record:	Cooper Carry Inc.
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/17/2019
Disposition:	Approved	Date Completed:	1/7/2020

### Status Statement

Note: Café Fire Sprinkler System

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

- |                            |             |
|----------------------------|-------------|
| 1. Fire Suppression System | 2019-FS-355 |
|----------------------------|-------------|