
Plan Review Summary

Building Information

Project Name:	ACC Network Ops. Fire Alarm ASBUILT	Floor/Room #:	First and Second Floors
Building #:	32	Department:	Athletics
Occupancy Type:	Business	Budget:	\$10,000,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	Jim Winer-Make3 Arch
Construction Manager:	Carla Barbour
Aim Project Number:	C0404-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/26/2019
Disposition:	Declined	Date Completed:	2/26/2019

Status Statement

Note: Fire Alarm As-builts

Review Comments:

1. There appears to be 17 devices not tested when checking the riser diagram with the central station test report. I have circled the devices in red on the riser diagram that were not tested and not on the central station report.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm
-