
Plan Review Summary

Building Information

| | | | |
|--------------------|-------------------------------------|-----------------|--------------|
| Project Name: | NEETRAC Phase IV Expansion Building | Floor/Room #: | New Building |
| Building #: | 777 | Department: | NEETRAC |
| Occupancy Type: | Business | Budget: | \$1,800,000 |
| Construction Type: | IIB | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|---------------------------------------|
| Project Manager: | Kynthia Gaines |
| Architect/Engineer of Record: | Stuart Thiel, Plexus R+D Architecture |
| Construction Manager: | Kynthia Gaines |
| Aim Project Number: | 0410-2017 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 3/1/2019 |
| Disposition: | Declined | Date Completed: | 3/4/2019 |

Status Statement

Note: Fire Alarm Revision

Review Comments:

1. Previous comments still exists. Please answer and address previous comments and provide a narrative.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
 2. Fire Suppression System
 3. Fire Alarm
-