

---

## Plan Review Summary

---

### Building Information

Project Name:	Emergency Generator Replacement-Howell Residence Hall	Floor/Room #:	
Building #:	010	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Robertson Loia Roof
Construction Manager:	Spencer Sheffield
Aim Project Number:	0466-2018

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/6/2019
Disposition:	Declined	Date Completed:	3/7/2019

---

### Status Statement

Note: Generator

### Review Comments:

1. Please provide the polyethylene pipe sizing table used from NFPA 54 and provide the total BTU's of the generator.
2. Please provide a sign next to the electric meter indicating that a generator is installed at this location.
3. Please provide the manufacturer specifications of the new generator.
4. Please acknowledge that a rough underground inspection will be performed and a pressure test of the piping.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation
-