

---

## Plan Review Summary

---

### Building Information

Project Name:	O'Keefe ROTC Interior Finishes	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities
Occupancy Type:	Business	Budget:	\$800,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	
Architect/Engineer of Record:	Lisa Vanderloo
Construction Manager:	Mitchell Shelton
Aim Project Number:	0421-2018

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/11/2019
Disposition:	Declined	Date Completed:	3/13/2019

---

### Status Statement

Note: Renovation of Army, Navy, Air Force, Marines

### Review Comments:

1. Are being renovated will have to be sprinkled
2. Emergency lighting required for corridors
3. Door stoppers are not permitted on any fire rated doors
4. Altering fire rated doors has to be compliant with UL listing of doors

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Permits Required:

1. Construction / Interior Renovation
  2. Fire Suppression System
  3. Fire Alarm
- 

2019-PR-066