
Plan Review Summary

Building Information

Project Name:	College of Computing-Auditorium 017 Renovation	Floor/Room #:	Ground
Building #:	050	Department:	CPSM
Occupancy Type:	Business	Budget:	\$646,062
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Schneider Wright
Construction Manager:	Jennifer Disotell
Aim Project Number:	0383-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/8/2019
Disposition:	Declined	Date Completed:	4/10/2019

Status Statement

Note: Fire Alarm Control Panel Replacement

Review Comments:

1. The fire alarm control panel shall be compatible with the Onyx Works station in accordance with Fire Marshal requirements. The Siemens Cerberus PRO is not compatible.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm
-