

Plan Review Summary

Building Information

Project Name:	O'Keefe ROTC Interior Finishes	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$999,999.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Warner Summers
Construction Manager:	Mitchell Shelton
Aim Project Number:	0421-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/15/2019
Disposition:	Declined	Date Completed:	4/15/2019

Status Statement

Note: Fire alarm devices change, removal and relocation

Review Comments:

1. Provide Battery calculations and voltage drops
2. Provide existing panel capacity
3. Provide construction type
4. Provide occupancy type
5. Show point of reference for North
6. Define better the removal of devices and the relocation of devices

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm