
Plan Review Summary

Building Information

Project Name:	Whiteley Lab Fit-Up-Cherry Emerson	Floor/Room #:	1st Floor
Building #:	66A	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$900,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Elba St. Romain (LAS)
Construction Manager:	Fenella Bryant
Aim Project Number:	0347-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/2/2019
Disposition:	Declined	Date Completed:	5/2/2019

Status Statement

Note: Addition of strobes and smokes

Review Comments:

1. Please provide verification that the existing horn/strobes will be compatible with the new ones, and that synchronization will not be an issue.
2. Strobes listed are Wheelock and specs given were Notifier, Notifier parts shall be used unless no other parts are available.
3. Batt Calcs unreadable
4. Room next to C105 needs address and a smoke added

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm
-