
Plan Review Summary

Building Information

Project Name:	GT CODA-AS BUILTS	Floor/Room #:	Floors 5-16
Building #:	207	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$23000000
Construction Type:	IA	Type of Review:	Fire Alarm-AS BUILTS

Project Management

Project Manager:	Nancy Cartledge
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	Christian Sanders
Aim Project Number:	0009-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/13/2019
Disposition:	Declined	Date Completed:	5/14/2019

Status Statement

Note: Fire Alarm As-builts

Review Comments:

1. The central station testing report shall have the node, loop, and module number of each fire alarm initiating device sending a signal. The central station testing report submitted does not include this data.

Permits Required:

1. Fire Alarm
-