
Plan Review Summary

Building Information

Project Name:	ROTC Interiors-O'Keefe Fire Alarm	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$999,999
Construction Type:	IIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	
Architect/Engineer of Record:	Warner Summers
Construction Manager:	Mitchell Shelton
Aim Project Number:	0459-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/22/2019
Disposition:	Declined	Date Completed:	5/23/2019

Status Statement

Note: Fire Alarm Upgrade 1st and 2nd floor

Review Comments:

1. Please revise from horn/strobes to strobes in all the restrooms.
2. Please provide smoke detectors at these locations: 1st floor data closet 134A; 1st floor storage closet above office 135; 1st floor storage closet 137A; 2nd floor door holder smoke detector in S200 corridor; 2nd floor janitor closet 208D; 2nd floor janitor closet 212A.
3. The color of horn/strobe required in be installed is white; the specs have red highlighted. Please revise.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-