
Plan Review Summary

Building Information

Project Name:	Bunger-Henry Battery Lab 433C	Floor/Room #:	433C
Building #:	086	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Hera
Construction Manager:	Mark Wood
Aim Project Number:	0228-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/10/2019
Disposition:	Declined	Date Completed:	6/18/2019

Review Comments:

1. Please provide proof that the lab will have a negative pressure with respect for the corridor and non-lab work areas in accordance with NFPA 45; previous comment number 6.
2. Please provide piping for gas cylinders delivery system per NFPA 45. I could not locate this information on the plumbing plans; previous comment number 3.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Construction / Interior Renovation
 2. Fire Suppression System
 3. Fire Alarm
-