
Plan Review Summary

Building Information

Project Name:	AHU Replacement for Lecture Halls 016 & 017	Floor/Room #:	Mechanical Room
Building #:	050	Department:	Facilities
Occupancy Type:	Assembly	Budget:	\$319,660.00
Construction Type:	IIA	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Robert Sanchez
Construction Manager:	Mark Wood
Aim Project Number:	0093-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/18/2019
Disposition:	Declined	Date Completed:	6/18/2019

Review Comments:

1. AHU-3 indicates over 4000 CFM being used. Please provide a duct smoke detector in the supply side of the unit as required per NFPA 90A and the IMC over 2000 CFM. Please have the duct smoke detector send a supervisory signal to the fire alarm control panel.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
 2. Fire Alarm
-