
Plan Review Summary

Building Information

Project Name:	Dalney Building-As-Builts	Floor/Room #:	All
Building #:	204	Department:	GTRC, PTS
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	AS-Builts

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/19/2019
Disposition:	Declined	Date Completed:	6/20/2019

Status Statement

Note: Fire Alarm As-builts and Central Station Testing Report

Review Comments:

1. It appears the following devices were not tested and were not included in the Central Station Testing Report:

1st floor devices: all devices were not tested

2nd floor devices: L1M018, L1M019, L1M020, L1M024, L1M029, L1M027, L1M028, L1M026, L1M022, L1M023

3rd floor devices: L2M006, L2D036, L2D018, L2D025, L1M003, L1M004, L2D030, L2M005

4th floor devices: L2M022, L2D078, L2D079, L2D057, L2D071, L2D072, L2M013, L2M014, L2M015, L2M016, L2M017, L2M018, L2M019, L2M020
