

---

## Plan Review Summary

---

### Building Information

Project Name:	Holland Plant-Breakroom	Floor/Room #:	Floor 1
Building #:	026	Department:	Facilities
Occupancy Type:	Other	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	William T. Oswell
Construction Manager:	
Aim Project Number:	0163-2017

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/1/2019
Disposition:	Declined	Date Completed:	7/2/2019

---

### Status Statement

Note: Breakroom in old coal holding area

### Review Comments:

1. Travel distance is exceeded
2. Can exit from a lower hazard into a higher one

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
  2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)
-