

## Plan Review Summary

### Building Information

Project Name:	Dalney Building-As-Builts	Floor/Room #:	All
Building #:	204	Department:	GTRC(office), PTS (Garage)
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	AS-Builts-Fire Alarm

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/1/2019
Disposition:	Declined	Date Completed:	7/2/2019

### Status Statement

Note: Fire Alarm As-builts and Central Station Testing Report

### Review Comments:

1. Previous comments dated 6/20/2019 still need to be addressed as noted below:

1<sup>st</sup> floor: Not all devices tested

2<sup>nd</sup> floor: L1M018, L1M029, L1M022, L1M023 - on riser not tested; L1M019, L1M020, L1M027, L1M028, L1M026 – Not on Riser

3<sup>rd</sup> floor: L2M006, L2D018, L2D025, L2D030 – on riser not tested; L2D036, L2M065 – not on riser

4<sup>th</sup> floor: L2M022, L2D078, L2D079, L2D057, L2D071, L2D072, L2M013, L2M014, L2M015, L2M016, L2M017, L2M019 – on riser not tested; L2M018, L2M020 – not on riser

2. New comments dated 7/2/2019:

The following devices were on the Central testing report and tested but not on the riser diagram in the plans:

N1L2M3, N1L1M34, N1L2M10, N1L1D99, N1L1M33 – NOT ON RISER DIAGRAM

3. Based on this being the second review and still no approval, I am requesting that the entire system be tested and the Central Station Testing Report submitted will contact IDs on both the riser diagram and the testing report of each device. If revisions are needed please have them done before 3<sup>rd</sup> submittal. This will eliminate all the confusion of what was tested before and what was not tested before and so on. Please review and make certain all information matches regarding the Central Station Testing Report and the riser diagram before submittal. Thank you.

### Plan / Shop Drawings Required:

1. Fire Alarm