

Plan Review Summary

Building Information

Project Name:	MRR FY19 Fire Alarm System Upgrades-Cherry Emerson	Floor/Room #:	All Floors
Building #:	066	Department:	GT Fire Safety Office
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0336-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/9/2019
Disposition:	Declined	Date Completed:	7/11/2019

Status Statement

Note: New Fire Alarm System

Review Comments:

- There are no smoke detectors in the following rooms; please revise plans and show smoke detectors installed in these rooms.
 - FA1: 1st floor; JAN B132, U/M C152A, JAN D103A, FLAV B131, MLAV D100 AND D104A, MLAV B130
 2nd floor; JANITOR 242, JANITOR 218H, OPLBSV 238B, U/M 218K, OFFSTO 211A, FLAV 246, MLAV 245A, MLA 218I
 - FA2: 3rd floor; JAN 360A, JAN 364A, FLAV 360, MLAV 362, FLAV 364
 Penthouse; U/M 401, GRNHSE 404

General Note:

- Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
- Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting
- 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)